

**ATA AIRLINES, INC.**

PORTABLE HALON FIRE EXTINGUISHERS

PAGE 1 / 2

CHECK BEING PERFORMED: Custom

ZONES: 200  
A/C NUMBER:  
REV. DATE: 08/06/04  
FREQUENCY: 1C

W/C NUMBER: 222F2601      DATE:  
W/O:  
JAC CODE:

**REFERENCES**

1

**MECH      INSP**

---

CHECK PORTABLE HALON FIRE EXTINGUISHERS FOR PROPER PRESSURE,  
WEIGHT AND CONDITION.

FAA ORDER: 8300.10

MPD ITEM: 26-26-01-6A

1. Halon Fire Extinguishers Inspection/Check (Fig. 1)

A. Accomplish the following procedure to the portable halon  
fire extinguisher.

- (1) Make sure the instruction decal and the nameplate  
are in good condition.
- (2) Make sure the mounting bracket is attached correctly  
to the airplane.
- (3) Make sure the extinguisher is installed tightly to  
the mounting bracket.
- (4) Make sure the lock-pin or lock-wire is correctly  
installed on the handle.
- (5) Examine the pressure gage and make sure the  
extinguisher has the correct pressure.
- (6) Make sure there is no physical damage to the  
extinguisher.
- (7) Make sure the weight of the extinguisher is not less  
than the weight show on the extinguisher nameplate.  
Record each bottle weight and location below.
- (8) If there are other manufacturer inspection or  
maintenance procedures that show on the extinguisher,  
do these procedures.

PORTABLE HALON FIRE EXTINGUISHERS

A/C NUMBER:

CHECK BEING PERFORMED: Cust

W/C NUMBER: 222F2601 (continued)

MECH: INSP:

(9) Verify that the bottle has a current and legible M-21 form affixed to it.

(a) "Date of Next Insp./Expiration" should be marked N/A.

(b) "Date of Last Inspection" should reflect date of last hydrostatic test.


B. Accomplish the procedure in step 1. A. to each Portable Halon Fire Extinguisher. Record location accomplished, part number (P/N), serial number (S/N), and weight of bottle below. Use the EEL to determine extinguisher location. N/A last signoff if EEL shows aircraft is configured with 3 extinguishers.

	Location	P/N	S/N	Weight
XXXX	_____	_____	_____	_____
XXXX	_____	_____	_____	_____
XXXX	_____	_____	_____	_____
XXXX	_____	_____	_____	_____

XXXX	_____	_____	_____	_____
XXXX	_____	_____	_____	_____
XXXX	_____	_____	_____	_____
XXXX	_____	_____	_____	_____

\*\*\*\*\*END OF WORKCARD\*\*\*\*\*

222F2601



HALON PORTABLE  
EXTINGUISHER

FIGURE 1

08/06/1998